



Mead & Hunt, Inc.

Addendum No. 2

Project name:	CIU Building 422	Client:	EDC of Chippewa County
Project location:	Kincheloe, Michigan	Client Contact:	Kathy Noel
Project number:	05143-00-09003/10005	Mead & Hunt manager:	Tim Mathys
Date:	July 26, 2010	Mead & Hunt phone:	608-273-6380

TO ALL BIDDERS: You are requested to make all changes and/or additions contained in this Addendum to the Bidding Documents. Failure to acknowledge this Addendum in Proposal shall result in rejection of bid.

BID DATE AND TIME SHOULD CORRESPOND TO DATE AND TIME INDICATED IN ADVERTISEMENT FOR BIDS, UNLESS DATE AND TIME HAS BEEN CHANGED IN THIS OR PREVIOUS ADDENDUMS.

I. CHANGES TO BIDDING REQUIREMENTS:

A. No Changes

II. CHANGES TO SPECIFICATIONS:

A. SECTION 083613 – SECTIONAL DOORS

ADD, on page 083613-6, 2.7, A., 1., the following: **i. Clopay Building Products; a Griffon company.**

B. SECTION 133419 – METAL BUILDING SYSTEMS

ADD, on page 133419-5, 2.6, the following:

B. Insulation shall be NAIMA 202-96 Standard and ASTM C 991 Type 2, having a thickness of 8 inches total in the roof, consisting of 2” unfaced insulation placed over purlins and 6 inches faced insulation between purlins, and 6 inches in the walls, consisting of 2” unfaced insulation placed over purlins and 4 inches faced insulation between purlins.

C. Insulation shall be faced one side with white polypropylene film, metallization, fiberglass and polyester scrim, 14 lb. white kraft (WPM-10).

III. CHANGES TO DRAWINGS:

A. SHEET CD-101 – SITE DEMOLITION PLAN

ADD, at Site Plan General Notes, the following:

2. Provide excavation of soil, gravel, and bituminous paving as required and to depth needed to provide new bituminous paving as shown on Sheet C-101.

B. SHEET C-101 – SITE IMPROVEMENTS PLAN

CLARIFY that pavement hatched located north and south of SRE Addition, north and south of Service/ARFF Building and Addition to be bituminous pavement per detail 3/C-501.

END OF ADDENDUM